

WELL CERTIFICATION CHECKLIST

	TYPE OF WATER USE AND DAILY DEMAND VALUE	Three Part Pump Test	Aquifer Test & Hydrogeologic Report	Timing of Well Certification	
1	Existing improved or unimproved residential lot with a proposed daily demand of $\leq 900^1$ gallons	YES	N/A		Prior to issuance renewal or extension of Building Permit
2	Existing improved or unimproved residential lot with a proposed daily demand of > 900 gallons.	N/A	YES		
3	Residential lot that is part of an approved subdivision with an approved Hydrogeological Report	N/A	YES		
4	Change in Use ² that requires additional water when the total daily demand will be > 900 gallons, unless the well has been previously certified for the amount of water proposed	N/A	YES		Prior to approval of Change in Use (2)
5	Subdivision of one (1) lot (excluding the remaining lands)	YES	N/A		Prior to issuance , renewal or extension of Building Permit
6	Subdivisions of 2 or more lots ³ (excluding the remaining lands)	N/A	YES		Prior to approval as to suitability of subdivision
7	Agricultural Subdivision of one (1) lot (excluding the remaining lands)	YES	N/A		Prior to issuance , renewal or extension of Building Permit
8	Agricultural Subdivision of two (2) or more lots ³ (excluding lands remaining)	N/A	YES		Prior to issuance , renewal or extension of Building Permit
9	Non-residential or multiple residence uses ≤ 900 gpd	YES	N/A		Prior to Preliminary Site Plan Approval
10	Non - Residential or multiple residence uses > 900 gpd	YES	N/A		
11	Any use $\geq 100,000$ gpd	OBTAIN NJDEP WATER ALLOCATION PERMIT			
12	Public Water Systems				
13	3 Copies of the Kingwood Township Water Testing Report	YES	YES	YES	
14	3 Copies of County Receipt	YES	YES	YES	
15	3 Copies of Application	YES	YES	YES	

¹ An equivalent of 4 bedrooms (200 gpd/bedroom).

² Any new or expanded water use that was not part of the original well certification (i.e., providing an off-site water supply, addition of bedroom(s), and other non-certified water uses), or in addition to the estimated water use (based on N.J.A.C. 7:10-12.6) if no certification was required at the time the well was installed. Off-site water supply shall only be conveyed to an adjacent single-family residence.

³ Unless the total proposed daily demand is ≤ 900 gpd, whereby the Three-Part Pump Test shall be applied to each well.